

Drinking Water Quality Report for Berryfields Supply Zone ZTW0301

Areas covered by Report:	Berryfields, Aylesbury
Report Period:	01 January 2019 to 31 December 2019
Upstream Zone:	Thames Water Aylesbury North WSZ (Z0156)
Population:	6054
Notices:	n/a

Commentary on Water Quality

The water supplied to the Berryfields Zone originates from a ground water source that is chlorinated. The analysis results indicate the quality of the water supplied to this zone is very good with no contraventions recorded or detected during 2019.

There were 3 customer contacts concerning "Taste", 1 concerning "Water Quality Report", 1 concerning "Illness" and 1 concerning "Appearance" during the period of this report. The investigations by IWNL concluded that the water supplied was compliant with regulations.

Hardness Rating:	The water supplied to this zone is classified as hard as it contains naturally elevated concentrations of calcium and magnesium.					
	Soft	Moderately Soft	Slightly Hard	Moderately Hard	Hard	Very Hard
CaCO ₃ mg/l	0-50	50-100	100-150	150-200	200-300	300+

Microbiological Indicators

Parameter	units of measurement	Number of Samples	Minimum	Maximum	Average	Prescribed Concentration or Value
Coliform Bacteria (Indicator)	No. 100/ml	24	0	0	0.0	0
E.coli (faecal coliforms Confirmed)	No. 100/ml	24	0	0	0.0	0
Enterococci (Confirmed)	No. 100/ml	12	0	0	0.0	0
Sulphite-reducing Clostridia (Confirmed)	No. 100/ml	13	0	0	0.0	0

Physio-Chemical Parameters

Parameter	units of measurement	Number of Samples	Minimum	Maximum	Average	Prescribed Concentration or Value
Ammonium (Total)	mg/l NH ₄	13	0.004	0.004	0.0040	0.5
Boron	mg/l B	12	0.02	0.03	0.028	1
Bromate	ug/l BrO ₃	12	0.1	0.1	0.10	10
Chloride	mg/l	13	23.1	27.4	24.69	250
Colour	mg/l Pt/Co	13	1	1.2	1.02	20
Cyanide (Total)	ug/l CN	12	0.7	0.9	0.72	50

Physio-Chemical Parameters continued						
Parameter	units of measurement	Number of Samples	Minimum	Maximum	Average	Prescribed Concentration or Value
Electrical Conductivity	uS/cm @ 20 C	13	532	570	546.8	2500
Fluoride (Total)	mg/l F	12	0.11	0.13	0.122	1.5
Free Residual Chlorine	mg/l	24	0.19	0.59	0.36	No Specific PCV
Hydrogen ion	pH value	13	7.24	7.5	7.381	6.5-9.5
Nitrate (Total)	mg/l NO3	12	22.3	26.1	24.73	50
Nitrite - Consumer's Taps	mg/l NO3	12	0.002	0.002	0.0020	0.5
Nitrite/Nitrate formula	No Units	12	0.45	0.52	0.494	1
Sodium	mg/l Na	12	11.7	15	12.83	200
Sulphate	mg/l SO4	13	17.6	22.4	19.33	250
Total Residual Chlorine	mg/l	24	0.25	0.66	0.449	No Specific PVC
Turbidity (CT)	FTU	13	0.07	0.22	0.120	4

Hydrocarbons / Organics						
Parameter	units of measurement	Number of Samples	Minimum	Maximum	Average	Prescribed Concentration or Value
1 1 1-Trichloroethane (Total)	ug/l	9	0.04	0.18	0.068	0.1
1 2-Dichloroethane (Total)	ug/l	9	0.07	0.1	0.073	3
Benzene (Total)	ug/l	9	0.02	0.07	0.026	1
Benzo[a]Pyrene (Total)	ug/l	8	0.00022	0.00023	0.000221	0.01
Benzo[b]Fluoranthene (Total)	ug/l	8	0.00052	0.0008	0.000555	The sum of PAHs must be <0.1 ug/l
Benzo[ghi]Perylene (Total)	ug/l	8	0.0004	0.0004	0.000400	The sum of PAHs must be <0.1 ug/l
Benzo[k]Fluoranthene (Total)	ug/l	8	0.00047	0.00047	0.000470	The sum of PAHs must be <0.1 ug/l
Bromodichloromethane (Total)	ug/l	9	2.52	3.9	3.419	60
ChloroDibromomethane (Total)	ug/l	9	4.72	6.46	5.870	100
Indeno[1 2 3-cd]Pyrene (Total)	ug/l	8	0.00048	0.00051	0.000484	The sum of PAHs must be <0.1 ug/l
Polycyclic Aromatic Hydrocarbons (Total by Calculation)	ug/l	8	0.009	0.08	0.049	0.1
Tetrachloroethene (Total)	ug/l	9	0.05	0.39	0.093	10
Tetrachloromethane (Total)	ug/l	9	0.02	0.14	0.037	3
Total Organic Carbon	mg/l C	13	0.7	1	0.78	NO ABNORMAL CHANGE
Total Trichloroethene & Tetrachloroethene (Total by Calculation)	ug/l	9	0	0.25	0.0	100

Hydrocarbons / Organics continued

Parameter	units of measurement	Number of Samples	Minimum	Maximum	Average	Prescribed Concentration or Value
Tribromomethane-Bromoform (Total)	ug/l	9	2.26	4.15	3.081	100
Trichloroethene (Total)	ug/l	9	0.05	0.34	0.104	10
Trichloromethane-Chloroform (Total)	ug/l	9	0.31	1.88	1.332	300
Trihalomethanes (Total by Calculation)	ug/l	9	11.12	15.12	13.702	100

Metals

Parameter	units of measurement	Number of Samples	Minimum	Maximum	Average	Prescribed Concentration or Value
Aluminium (Total)	ug/l Al	12	3.21	7.22	6.552	200
Antimony	ug/l Sb	12	0.04	0.25	0.105	5
Arsenic (Total)	ug/l As	12	0.24	0.58	0.324	10
Cadmium (Total)	ug/l Cd	12	0.006	0.013	0.0113	5
Chromium (Total)	ug/l Cr	12	0.22	0.63	0.380	50
Copper (Total)	mg/l Cu	12	0.0088	0.559	0.07051	2
Iron (Total)	ug/l Fe	12	0.7	1.73	0.951	200
Lead (10)	ug/l Pb	12	0.03	0.43	0.144	10
Manganese (Total)	ug/l Mn	12	0.14	0.22	0.207	50
Mercury (Total)	ug/l Hg	12	0.02	0.05	0.031	1
Nickel (Total)	ug/l Ni	12	0.99	3.36	1.525	20
Selenium (Total)	ug/l Se	12	0.41	1.28	0.721666667	10

Organoleptic Parameters

Parameter	units of measurement	Number of Samples	Minimum	Maximum	Average	Prescribed Concentration or Value
Odour (Quantitative)	Dilution Number	13	0	0	0.0	0
Taste(Quantitative)	Dilution Number	13	0	0	0.0	0

Notes

1. For some parameters, monitoring occurs at the supplying Water Treatment Works rather than the Water Supply Zone.

Glossary of Terms

Term	Definition
PCV	Prescribed Concentration or Value
mg/l	Milligrammes per Litre or parts per million
µg/l	Microgrammes per Litre or parts per billion
Pt/Co	Platinum/Cobalt
µS/cm	Micro Siemens per Centimetre
Bq/l	Becquerel per Litre
NTU	Nephelometric Turbidity Units
